

Section 25 25 50 –Single Purpose Docking Station with Rotary Manual Transfer Switch

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. The requirements of the General Conditions, Supplementary Conditions, Division 1, Division 20, and Drawings apply to all Work herein.
- B. Requirements of the following Division 20-28 Sections apply to this section:
 - 1. Design Criteria - Section 20 05 02
 - 2. Basic Division 20-28 Requirements - Section 20 05 03
 - 3. General Division 20-28 Materials and Methods - Section 20 05 05
 - 4. Schedule of Submittal Data - Section 20 05 04
 - 5. Scope of Work - Section 26 05 01
 - 6. Testing - Section 26 05 07

1.2 SCOPE

- A. General: Furnish and install a single purpose temporary generator docking station as shown, scheduled, and specified.
- B. Related Sections: Other Division 20-28 Sections contain requirements related to the work of this Section. These may include, but not be limited to, the following sections:
 - 1. Packaged Electric Generating Systems - Section 26 32 13.13

1.3 QUALITY ASSURANCE

- A. Manufacturers: If they comply with these specifications and requirements, products of the following manufacturers will be acceptable:
 - 1. Single Purpose Docking Station with Rotary Manual Transfer Switch:
 - a. Power Temp Systems
- B. Codes and Standards:
 - 1. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, by a qualified testing agency, and marked for intended location and application.
 - 2. Comply with NFPA 70.

1.4 GUARANTEE/WARRANTY

- A. The equipment installed under this contract shall be left in proper working order.
- B. Manufacturer's Warranty: Manufacturer shall repair or replace components of Docking Station that fail(s) in materials or workmanship withing specified warranty period.
 - 1. Warranty Period: One year(s) from date of Substantial Completion

PART 2 - PRODUCTS

2.1 SINGLE PURPOSE DOCKING STATIONS

- A. Docking station shall include 16 Series Cam-lok Panel Mounts for use as connection to Portable Generator.
- B. Entire package must be listed to ETL or UL 1008 Standards. UL listing of individual components is not acceptable.
- C. Enclosures:
 - 1. NEMA 3R rain-tight, 304 GA aluminum enclosure
 - a. Pad-lockable front door shall include a hinged access plate at the bottom for entry of cables from portable generator or portable load bank. NEMA 3R integrity shall be maintained with access plate open for cable entry.
 - b. Front and side through a front access panel shall be accessible for maintenance.
 - c. Top, side, and bottom through a front access panel shall be accessible for permanent cabling.
 - 2. Finishes:
 - a. Paint after fabrication. Powder coated Gray.
- D. Phase, Neutral, and Ground Buses:
 - 1. Material: Silver-plated Copper.
 - 2. Equipment Ground Bus: bonded to box.
 - 3. Ground Bus: 50% of phase size.
 - 4. Neutral Bus: Neutral bus rated 100 percent of phase bus.
 - 5. Round edges on bus.
 - 6. Cam-loks shall be sized in increments of 400A per docking station total ampacity
 - a. Underrated bussing and Cam-loks are not acceptable.
 - b. Providing additional Cam-loks exceeding the total ampacity of the docking station is not acceptable.
 - c. Cam-loks shall be 45° to reduce cable torque on temporary generator docking panels.
 - d. Temporary Connectors shall include protective flip lids to prevent accidental contact.
- E. Temporary generator connectors shall be Hardwired and Cam-lok style.
 - 1. Cam-loks shall be color coded according to system voltage:
 - a. A phase – Black or Brown.
 - b. B phase – Red or Orange.
 - c. C phase – Blue or Yellow.
 - d. N Neutral – White.
 - e. G Ground – Green.
 - 2. Hardwire shall be accomplished utilizing Repetitive Use Smart Lug.
 - a. Rated for #6-350MCM Conductor.
 - b. Spinning Bolt tip to compress wire with no knurling of conductor.
 - 3. Smart Lug shall be mounted on T-Slot Smart Buss System and allow for adjustable placement of Smart Lug in field.
 - a. Smart Buss System shall be rated for 30,000V.

- F. Temporary connectors shall include protective flip lids to prevent accidental contact.
- G. Permanent connectors shall be broad range set-screw type, located behind an aluminum barrier
 - 1. Appropriate quantity of lugs shall be provided to allow pass-through of conductors.
- H. Voltage & Current Rating:
 - 1. Voltage and current rating shall be as indicated, scheduled, or specified.
- I. Phase Rotation, Bonding, and Overcurrent Protection:
 - 1. Source cable connection points shall be clearly marked with phase rotation, system bonding requirements, and maximum temporary generator overcurrent protection rating.
- J. Additional accessories shall be included in submittal drawings as follows:
 - 1. Extra Depth for Bottom Conduit Access
 - 2. Contact point that shall annunciate at facility fire alarm system to indicate that the permanent emergency source is disconnected from the emergency system.
 - 3. Listed Monitoring Device

PART 3 - EXECUTION

3.1 SINGLE PURPOSE DOCKING STATION

- A. Shop drawing submittal shall include, but not be limited to, the following:
 - 1. Cut sheets of the docking station with construction, fault current ratings, and with bus amperage, voltage, phase and wires, and all associated accessories clearly indicated.
 - 2. Additional information as required in Section 20 05 03.
- B. INSTALLATION
 - 1. Install docking station as shown, including electrical connections, in accordance with the manufacturer's written instructions, the applicable requirements of NEC and recognized industry practices to ensure that products serve the intended function.
 - 2. Coordinate installation of docking station with cable and raceways installation work.
 - 3. Anchor enclosures firmly to walls and structural surfaces ensuring that they are permanently and mechanically secured. Provide unistrut racks where walls cannot support panels.
 - 4. Install each floor-mounted docking station on a 4-inch reinforced concrete housekeeping pad. The housekeeping pad shall extend 3-inches beyond the housing of the docking station, any block outs, dimensions, and location of the concrete work.

END OF SECTION 262550